

**PERFORMA REGARDING SAFE DRINKING WATER AND
SANITARY CONDITION CERTIFICATE**

No: 194

Date: 03-03-2025

It is certified that an inspection team headed by **Er. Manish Sub Divisional Engineer from Water Supply & Sanitation Department Sub Division No.1 Abohar** inspected, **GODWIN PUBLIC SR.SEC.SCHOOL,VILLAGE GHALLU,DISTT FAZILKA** and found that the school has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school as per the norms prescribed by the Central/State/U.T. Govt.

The above Certificate is valid for a period of One Year.

Signature of Seal

Manish

Sub Divisional Engineer
Water Supply & Sanitation
Sub Division No. 1 Abohar

Name . - Manish

Designation. - Sub Divisional Engineer

To,

GODWIN PUBLIC SR.SEC.SCHOOL,VILLAGE GHALLU,DISTT FAZILKA

[Signature]
Principal
Godwin Public Sr. Sec. School
(Affiliated to C.B.S.F.)
GHALLU (Distt. Fazilka)

[Signature]
Manager
Godwin Public Sr. Sec. School
(Affiliated to C.P.S.E.)
GHALLU (Distt. Fazilka)



BLOCK WATER TESTING LABORATORY, ABOHAR

Hanuman garh Road in Water works Near Bye pass, Abohar
bwtlabh@gmail.com

To,

GODWIN PUBLIC SR.SEC.SCHOOL
VILLAGE GHALLU P.O. NIHAL KHERA, DISTT. FAZILKA

No.: Abohar/2425/00368 Dated : 03/03/2025

Subject : Testing Reports of Water Samples.


Reference: Your Letter/SRF No. Letter No.-gpsghallu/1141/2025 Dated: 24/02/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 24/02/2025. It is request to fill the attached feedback form and send it back to Block Water Testing Laboratory, Abohar


D/A : Test Report



Authorized Signatory
For, Block Water Testing Laboratory
Abohar



Principal,
Godwin Public Sr. Sec. School
(Affiliated to C.B.S.E.)
GHALLU (Distt. Fazilka)



Manager
Godwin Public Sr. Sec. School
(Affiliated to C.P.S.E.)
GHALLU (Distt. Fazilka)

BLOCK WATER TESTING LABORATORY, ABOHAR

Hanuman garh Road in Water works Near Bye pass, Abohar
bwtlabh@gmail.com

TEST REPORT						
Name & Address of Customer : GODWIN PUBLIC SR.SEC.SCHOOL VILLAGE GHALLU P.O. NIHAL KHERA,DISTT. FAZILKA			Customer Reference No.		No : Letter No.-gpsghallu/1141/2025 Dated : 24/02/2025	
			Sample Submitted by		Abhilekh Sharma	
			Date of Sample Receipt		24/02/2025	
			Analysis Starting Date		24/02/2025	
			Analysis completion Date		25/02/2025	
Discipline : Chemical Testing			Group: Water			
ULR No.:			Sample Type :		Treated Water	
Test Report No.:		Abohar/2425/00368	Date of Issue :		03/03/2025	
Registration no.:		Abohar/REG2425/00758	Condition of Sample :		Sealed	
Collection Point:		Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:		1000 ml / Plastic Bottles	
Scheme/Source:		Not Mentioned(Not Mentioned)	Location/Depth :		Godwin Public School(RO Water) / NA	
Village :		Ghallu	Habitation :		Ghallu	
Block:		Khuian Sarwar	District :		Fazilka	
Latitude :		Not Mentioned	Longitude:		Not Mentioned	
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.12@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	155	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO ₃)	40	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO ₃)	56	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	13	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	6	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	42	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used : TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Mrs. Manju
Quality Manager
Authorized Signatory
For,Block Water Testing Laboratory
Abohar

Principal,
Godwin Public Sr. Sec. School
(Affiliated to C.B.S.F.)
GHALLU (Distt. Fazilka)

Manager
Godwin Public Sr. Sec. School
(Affiliated to C.P.S.E.)
GHALLU (Distt. Fazilka)

End of the Test Report